

TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-11-05-30-01

Product: Laminate floor coverings with the structures BS, BF, WG, RF, EX, OA, WO, PS, WF, SP, AS, SU, GL, LP, EW, RS, DB, NL


Producer: Kronoflooring GmbH
Mühlbacher Str. 1
01561 Lampertswalde / Dresden

Order: Determination of the slippery resistance according to EN 13893 /
classification according to EN 14041

Test reports: 265188
276279
279047
270181
271193


Result: The tested laminate floor coverings structures are fulfilling with the values of $\mu = 0,46 - 0,70$ the requirements of the class DS ($\mu \geq 0,30$) according to EN 14041 (CE-labelling).

Dresden, 30 May 2011



Head of laboratory





Engineer in charge